REC 16-154

KNOLLWOOD ENERGY

Knollwood Energy of MA LLC
P.O. Box 30
Chester, New Jersey 07930

NHPUC 14JAN'16AM11:18

January 12, 2016

Debra A. Howland
Executive Director
New Hampshire Public Utilities Commission
21 South Fruit Street, Suite 10
Concord, NH 03301-2429

Dear Ms Howland,

Enclosed please find applications for 12 systems to be part of the Knollwood Energy of MA LLC (NH-II-13-089) Class II Photovoltaic aggregation for New Hampshire Renewable Energy Certificates (RECs) generated from customer-sited sources, pursuant to New Hampshire Code of Administrative Rules Puc 2506.
Also enclosed are the Simplified Process Interconnection Application and Service Agreement, and the Certificate of Completion.

Electronic versions have been entered into the new online application system under batch number KN16003.

Jeff Egan	George Heavner
John Elkins	Susan Hemingway
Matt Erlick	Bobby Lambert – High St Solar
Albert Franz	Jeff Huckins
Justin Hart	John Straight
Bradford Hartwell	Stephen Rust

Please feel free to contact me with any questions or further instructions.
Thank you for your consideration,

Linda Modica
New England REC Operations Manager
Knollwood Energy of MA LLC
973.879.7826
linda@knollwoodenergy.com

REC 16-134

C

NH Public Utilities Commission

REC Aggregator Portal

New Users CLICK HERE to setup your account for this form. Creating an account enables you to partially complete the form and return later to finish it or to make changes after the form is submitted. Be sure to create your account BEFORE entering information into the form, or the information will be lost.

Existing Users CLICK HERE

Basic Information

Who is submitting this request?

Aggregator

Aggregator Batch Number

KN16003

Executive Director email

PUC - Executive.Director

Aggregator name

Knollwood Energy

Aggregator Email

linda@knollwoodenergy.com

Other Aggregator name

Other aggregator email address

Facility Owner Name

Stephen Rust

Facility Owner email

seneleteacher@msn.com

Owner Phone

603-573-6797

Facility Address

265 Patch Road

Facility Town/City

Hopkinton

Facility State

NH

Facility Zip

03229

Is the facility address the same as the owner's mailing address

- (●) Yes
- ( ) No

Mailing Address

Mailing Town/City

Mailing State

Mailing Zip

Primary Contact (who should we call with questions)

Linda Modica

Contact Phone

Other Email Address

Facility Information

Class

II

Utility

PSNH

Other Utility Name

To obtain a GIS ID contact:

James Webb

408 517 2174

jwebb@apx.com

GIS ID (include "NON")

NON55408

Date of Initial Operation

01/12/2016

Facility Operator Name, if applicable

Panel Quantity

40

Panel Make

Canadian Solar

Panel Model

Other

Panel Rated Output

250

System capacity based on panels

0.1000

Inverter Quantity

40

Inverter Make

Enphase Energy

Inverter Rated Output

215

Add'l Inverter Quantity

NA

Additional Inverter Make

None

Add'l Inverter Model

Rated Output - Primary Inverter

215

Rated Output - Additional Inverter

System capacity based on single inverter make

0.09

System capacity based on two inverter types

System capacity in mW as stated on the interconnection agreement

8.6

Revenue Grade Meter Make

GE

Was this facility installed directly by the customer (no electrician involved)?

- ○ Yes
- ◉ No

Electrician Name & Number

Other

Other Electrician Name & Number

Rich Potter 11696

Installation Company

Sun Dial Solar

Other Installation Company Name

Other Inst. Company Address

Other Inst. Company City

Other Inst. Company State

Other Inst. Company Zip

Independent Monitor Name & Company

Paul Button - Energy Audits Unlimited

Other Monitor Name and Company

Is the installer also the equipment supplier?

- (●) Yes
- ( ) No

Equipment Vendor

Please attach your completed interconnection agreement including Exhibit B.

https://fs30.formsite.com/jan1947/files/f-5-99-5864863_LPbhRJ0t_Rust_SPIA.pdf

The project described in this application will meeet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independant minitor or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independant monitor that the meter operaes according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facilitiy's interconnection agreement is attached.

Please attach additional document here

https://fs30.formsite.com/jan1947/files/f-5-168-5864863_dEVoDrB3_Rust_COC.pdf

Please attach additional document here

https://fs30.formsite.com/jan1947/files/f-5-173-5864863_zr9RNLeD_Rust_NHOS.pdf

Aggregator statement of accuracy

Sign your name using a mouse or, if you are using a touch-screen device, a stylus or other pointer.



Print Name

Linda Modica

Date Signed

01/12/2016

RECEIVED
FEB 20 2015
BY:

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA

Simplified Process Interconnection Application and Service Agreement

PSNH Application Project ID#: _____

Contact Information:

Legal Name and Address of Interconnecting Customer (or, Company name, if appropriate)

Customer or Company Name (print): Stephen Rust

Contact Person, if Company: _____

Mailing Address: 265 Patch Road

City: Hopkinton State: NH Zip Code: 03229 03229

Telephone (Daytime): 603-573-6787 (Evening): _____

Facsimile Number: _____ E-Mail Address: senele teacher @ msn.com

Alternative Contact Information (e.g. System installation contractor or coordinating company, if appropriate):

Name: SUNDIAL SOLAR NH

Mailing Address: 96 Hilliard Road

City: Chichester NH 03258 Zip Code: 603-961-0045

Telephone (Daytime): _____ (Evening): _____

Facsimile Number: _____ E-Mail Address: fuat@sunpialsolar nh.com

Electrical Contractor Contact Information (if appropriate):

Name: Richard Potter

Mailing Address: 101 Beaver Hill RE

City: Belmont State: NH Zip Code: 03220

Telephone (Daytime): 603-707-6827 (Evening): _____

Facsimile Number: _____ E-Mail Address: Rpotter.electric@yahoo.com

Facility Site Information:

Facility (Site) Address: SAME (CONFIRMED W/FUAT - FACILITY ADDRESS IS SAME.

City: _____ State: NH Zip Code: _____

Electric

Service Company: PSNH Account Number: 56-945696 009 Meter Number: G42426675

Account and Meter Number: Please consult an actual PSNH electric bill and enter the correct Account Number and Meter Number on this application. If the facility is to be installed in a new location, please provide the PSNH Work Request number.

PSNH Work Request # _____

Non-Default' Service Customers Only:

Competitive Electric

Energy Supply Company: N/A Account Number: N/A

(Customer's with a Competitive Energy Supply Company should verify the Terms & Conditions of their contract with their Energy Supply Company.)

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA

Simplified Process Interconnection Application and Service Agreement

Facility Machine Information:

Generator/ Canadian Solar Model Name & CS6P-250P

Inverter Manufacturer: Enphase Number: M215 Quantity: 40

.215 Nameplate Rating: ~~5,600~~ (kW)_____ (kVA) 240 (AC Volts) Phase: Single ☑ Three ☐

Nameplate Rating: The AC Nameplate rating of the individual inverter.

System Design Capacity: 8,600 (kW) _____ (kVA) Battery Backup: Yes ☐ No ☑

System Design Capacity: The system total of the inverter AC ratings. If there are multiple inverters installed in the system, this is the sum of the AC nameplate ratings of all inverters.

Net Metering: If Renewably Fueled, will the account be Net Metered? Yes ☑ No ☐

Prime Mover: Photovoltaic ☑ Reciprocating Engine ☐ Fuel Cell ☐ Turbine ☐ Other_____

Energy Source: Solar ☑ Wind ☐ Hydro ☐ Diesel ☐ Natural Gas ☐ Fuel Oil ☐ Other_____

Inverter-based Generating Facilities:

UL 1741 / IEEE 1547.1 Compliant **(Refer To Part Puc 906 Compliance Path For Inverter Units, Part Puc 906.01 Inverter Requirements)**

Yes ☑ No ☐

The standard UL 1741.1 dated May, 2007 or later, "Inverters, Converters, and Controllers for Use With Independent Power Systems," addresses the electrical interconnection design of various forms of generating equipment. Many manufacturers choose to submit their equipment to a Nationally Recognized Testing Laboratory (NRTL) that verifies compliance with UL 1741.1. This term "Listed" is then marked on the equipment and supporting documentation. ***Please include, any documentation provided by the inverter manufacturer describing the inverter's UL 1741/IEEE 1547.1 listing.***

External Manual Disconnect Switch:

An External Manual Disconnect Switch shall be **installed in accordance with 'Part Puc 905 Technical Requirements For Interconnections For Facilities, Puc 905.01 Requirements For Disconnect Switches and 905.02 Disconnect Switch.'**

Yes ☑ No ☐

Location of External Manual Disconnect Switch: Next to the Meter

Project Estimated Install Date: April 1st Project Estimated In-Service Date: April 20th

Interconnecting Customer Signature:

I hereby certify that, to the best of my knowledge, all of the information provided in this application is true and I agree to the **Terms and Conditions for Simplified Process Interconnections** attached hereto:

Customer Signature: [signature] Title: OWNER Date: 2/18/15

Please include a one-line and/or three-line diagram of proposed installation. Diagram must indicate the generator connection point in relation to the customer service panel and the PSNH meter socket. Applications without such a diagram may be returned.

For PSNH Use Only

Approval to Install Facility:

Installation of the Facility is approved contingent upon the Terms and Conditions For Simplified Process Interconnections of this Agreement, and agreement to any system modifications, if required.

Are system modifications required? Yes ☐ No ☑ To be Determined ☐

Company Signature: [signature] Title: SR. ENGINEER Date: 2-23-15



RECEIVED

MAY 21 2015

SESD

New Hampshire PUC REC Certification Application Owner Statements

The information provided on this application for New Hampshire Renewable Energy Certificate eligibility is accurate to the best of my knowledge and I authorize Knollwood Energy to act on my behalf in filing said application.

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor, or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

Elaine M. Rust

Printed Name of signature owner

Elaine M. Rust

Elaine M. Rust (Sep 15, 2015)

Signature of system owner